12-1400

Please test for the following highlightendrons

PART I

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Beginning the effective date of this permit and lasting until the expiration date, the permittee is authorized to discharge process wastewater, through discharge point # 2. Discharge through discharge point # 2 shall be limited and monitored by the permittee as specified below: [1]

	Discharge Limi	tations	Monitoring Rec	quirements
	Regulated Parameter	Maximum for Any one Day mg/L	Monitoring Frequency	Sample Type
	Cadmium[5]	.02	Semi-Annual	Composite[2]
	Total Chromium[5]	2.0	Semi-Annual	Composite[2]
	Copper[5]	0.60	Semi-Annual	Composite[2]
	Cyanide	0.50	Semi-Annual	Grab
7,000	Lead[5]	0.10	Semi-Annual	Composite[2]
	Nickel[5]	0.80	Semi-Annual	Composite[2]
	Silver[5]	0.24	Semi-Annual	Composite[2]
	Zinc[5]	1.25	1 X Week	Composite[2]
	Oil and Grease[6]	100	Semi-Annual	Grab
	TPH [6]	(Monitor and report)	Semi-Annual	Grab
	рН	6-10	Daily	Grab
	CBOD [4]	(Monitor and report)	1 X Month	Composite[2]
	Ammonia [4]	(Monitor and report)	1 X Month	Composite[2]
	COD [4]	(Monitor and report)	1 X Month	Composite[2]
	TSS [4]	(Monitor and report)	1 X Month	Composite[2]
	Flow	N/A	Daily [3]	
	тто	2.13	Semi-Annual	Grab
	Phenol	0.50	Semi-Annual	Grab
	Molybdenum[5]	(Monitor and report)	1 X Month	Composite[2]

Test meri	ica	Divisi	ion/L	.abo	ratory N	Nam	ie:		Inc	diana	apol		ision	1				is work	being c		ed for re	lytical me gulatory Yes	y pu	es?		
Client Name		Milbar	ık					_	Clie	nt #:	:							Enfo	rcemen	t Action		Yes	No			
Address:		Milbank Client #: 1400 East Havens Street Kokomo, IN 56901-3188											Report To: Mr. Richard Tyler													
City/State/Zip Code:													Invoice To:													
Project Manager:		Mr. Richard Tyler																		98.0060 PO#:						
Telephone Number:		765-452-5694 Fax:													Proj	ect Nam	e:	Weel	kly Was	tewater						
Sampler Name: (Print Name)																	Project	#:	N. 111 - N.							
Sampler Signature:																	ocation I							:IN		
					Matrix	Pre	eserv	ation	n & #	of C	Conta	ainers	,				Ana	lyze Fo	r:					1		
TAT Standard Rush (surcharges may apply) Other: Date Needed: Fax Results: Y N SAMPLE ID Weekly - Comp	Date Sampled	Time Sampled	G = Grab, C = Composite	Z Field Filtered	SL - Sludge DW - Drinking Water GW - Groundwater S - Soil/Soild WW - Wastewater Specify Other	HNO ₃ (Red Label)	HCI (Blue Label)	NaOH (Orange Label)	H ₂ SO ₄ Plastic (Yellow Label)	H ₂ SO ₄ Glass(Yellow Label)	None (Black Label)	_	ξ _χ X											QC DeliverablesNoneLevel 2(Batch QC)Level 3Level 4 Other:		
																+										
	± 2000000 100000000																									
											`															
Special Instructions:PLEASE COMPOSITE USING	FLOW R	EADING	S AT	TACH	1ED*****	**				`									LABC	Init La	RY CO b Temp ib Temp		rs:			
Relinquished By: Stylanus	Haber	12-19	5.EV	Time:	1.00pm	Rec	eive	d By	<i>/</i> :						Date		Time:			dy Seals	s: Y	N FestAme		N/A Y N		
Relinquished By:		Date:		Time):	Rec	eive	d By	<i>!</i> :						Date		Time:		1		, .					
Relinquished By:		Date:		Time	e:	Rec	eive	d B	y:						Date		Time:		Metho	d of Sh	ipment	i:	N	11L0005454		

DAILY: EVERY DAY SYSTEM RUNS

IX WEEK: DAY OF WEEK COMPOSITE IS TAKEN (USUALLY THURSDAY)

IX HONTH: TO BE TAKEN FIRST WEEK COMPOSITE IS TAKEN FOR THAT HONTH

SEMI-ANNUAL: TO BE TAKEN PIRST WEEK IN JUNE AND PIRST WEEK IN DECEMBER

PARTI

EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Beginning the effective date of this permit and lasting until the expiration date, the permittee is authorized to discharge process wastewater, through discharge point # 2. Discharge through discharge point # 2 shall be limited and monitored by the permittee as specified below: [1]

	Discharge Limit	ations		<u>N</u>	Monitoring Requ	<u>uirements</u>
	Regulated <u>Parameter</u>	Maximum for Any one Day mg/L	RESULT	DATE	Monitoring Frequency	Sample Type
Cd	Cadmium[5]	.02	2		Semi-Annual	Composite[2]
Cr	Total Chromium[5]	2.0			Semi-Annual	Composite[2]
Cu	Copper[5]	0.60			Semi-Annual	Composite[2]
Ca	Cyanide	0.50			Semi-Annual	Grab
PЬ	Lead[5]	0.10			Semi-Annual	Composite[2]
Ní	Nickel[5]	0.80			Semi-Annual	Composite[2]
	Silver[5]	0.24			Semi-Annual	Composite[2]
Zn	Zinc(5)	1.25	0.028	12-15-00	1 X Week	Composite[2]
FOG	Oil and Grease[6]	100			Semi-Annual	Grab
TIL+ GREASE YORO CARBONS	>TPH[6]	(Monitor and report)			Semi-Annual	Grab
	pН	6-10			Daily	Grab
	CBOD [4]	(Monitor and report)			1 X Month	Composite[2]
Nh3	Ammonia [4]	(Monitor and report)			1 X Month	Composite[2]
	COD [4]	(Monitor and report)		-	! X Month	Composite[2]
	TSS [4]	(Monitor and report)			1 X Month	Composite[2]
	Flow	N/A			Daily (3)	
*	тто	2.13			Semi-Annuai	Grab
	Phenol	0.50			Sem'-Annual	Grab
Mo	Molybdenum[5]	(Monitor and report)			LX Month	Composite[2]

IND TTO CERTIFICATION STATEMENT IN LIEU OF MONITORING ALONG WITH 40 CFR ATEGORICAL STATEMENT. MUST BE SENT EVERY JUNE AND DECEMBER (SEMI-ANNUAL)

ANALYTICAL REPORT

Mr. Richard Tyler MILBANK MANUFACTURING INC 1400 E. Havens Street Kokomo, IN 56901-3188

282156 WEEKLY - ZINC ONLY

12/13/2000

Job Number: 00.06628 Page 1 of 3

Enclosed are the Analytical Results for the following samples submitted to TestAmerica, Inc. Indianapolis Division for analysis:

Project Description: WASTEWATER ANALYSIS

Sample
Number Sample Description

Date Time Date
Taken Taken Received

11/30/2000 15:30 12/04/2000

TestAmerica, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed.

TestAmerica Incorporated-Indianapolis Division is in compliance with the National Environmental Laboratory Accreditation Program (NELAP) Standards.

Reproduction of this analytical report is permitted only in its entirety.

Project Representative

Test/America

7071 5 5001

ANALYTICAL REPORT

Mr. Richard Tyler

MILBANK MANUFACTURING INC

1400 E. Havens Street

Kokomo, IN 56901-3188

12/13/2000

Job No.: 00.06628

Page 2 of 3

Date Received: 12/04/2000

Job Description: WASTEWATER ANALYSIS

Sample Number / Sample I.D. Sample Date/ Analyst Reporting Parameters Wet Wt. Result Flag Units Date & Time Analyzed Method __Limit

282156

WEEKLY - ZINC ONLY

11/30/2000 15:30

Zinc, ICP

0.023

mg/L

out 12/08/2000 11:15 EPA 200.7

<0.020

Page 3 of 3

KEY TO ABBREVIATIONS

- Less than; when appearing in the result column, indicates analyte not detected at or above the Reporting Limit.
- Percent; To convert ppm to %, divide result by 10,000. To convert % to ppm, multiply the result by 10,000.
- * Indicates the Reporting Limit is elevated due to insufficient sample volume.
- mg/L Part per million; Concentration in units of milligrams of analyte per Liter of aqueous sample.
- ug/L Part per billion; Concentration in units of micrograms of analyte per Liter of aqueous sample.
- mg/kg Part per million; Concentration in units of milligrams of analyte per kilogram of non-aqueous sample.
- ug/kg Part per billion; Concentration in units of micrograms of analyte per kilogram of non-aqueous sample.
- a Indicates the sample concentration was quantitated using a diesel fuel standard.
- b Indicates the analyte of interest was also found in the method blank.
- c Sample resembles unknown Hydrocarbon.
- dw When indicated, the result is reported on a dry weight basis. The contribution of the moisture content in the sample has been subtracted when calculating the concentration.
- d1 Indicates the analyte has elevated Reporting Limit due to high concentration.
- d2 Indicates the analyte has elevated Reporting Limit due to matrix.
- e Indicates the reported concentration is estimated.
- g Indicates the sample concentration was quantitated using a gasoline standard.
- h Indicates the sample was analyzed past recommended holding time.
- i Insufficient spike concentration due to high analyte concentration in the sample.
- j Indicates the reported concentration is below the Reporting Limit.
- k Indicates the sample concentration was quantitated using a kerosene standard.
- Indicates an MS/MSD was not analyzed due to insufficient sample. An LCS / LCS Duplicate provided for precision.
- m Indicates the sample concentration was quantitated using a mineral spirits standard.
- o Indicates the sample concentration was quantitated using a motor oil standard.
- p Indicates the sample was post spiked due to sample matrix.
- q Indicates MS/MSD exceeded control limits. The associated sample may exhibit similar matrix bias. All other quality control indicators are in control.
- r Indicates the sample was received past recommended holding time.
- u Indicates the sample was received improperly preserved and/or improperly contained.
- uj Indicates the result is below the Reporting Limit and is considered estimated.
- z Indicates the BOD dilution water blank depletion was between 0.2 and 0.5 mg/L.

TestAmeri	ca	Divis	ion/L	abo	ratory N	Varr	ie:		Inc	diana	apoli	is Di	vision				work	being conpliance	onducte	ed for re		ry purpo		and Arrest schools and collection of the Arrest School and Arrest
Client Name		Milbai	nk						Clie	nt #:	:	\	<i>}</i>	_				rcemen		_	Yes	No	10.	-
Address:		1400	East	Have	ens Stree	ŧ									R	eport To);	Mr. F	Richard	Tyler			4.7	2 2001
City/State/Zip Code:		Kokor	no, IN	1 56	901-3188	3									In	voice To):							5001
Project Manager:		Mr. Ri	charc	d Tyle	er											Quote #						ŧ:		
Telephone Number		765-4	52-56	94				Fax:							Proje	ct Name	:	Week	dy Was	tewater	r			
Sampler Name: (Print Name)															F	Project #	:							
Sampler Signature:														;		ation ID							::	IN
					Matrix	Pre	eserv	ation	1 & #	of C	Conta	iners		<u> </u>		Analy	ze Fo	r:					7	
TAT Standard Rush (surcharges may apply) Other: Date Needed: Fax Results: Y N SAMPLE ID Weekly - Comp	Date Sampled	Time Sampled	O G = Grab. C = Composite	A Field Filtered	SL - Sludge DW - Drinking Water GW - Groundwater S - Soil/Soild WW - Wastewater Specify Other	oel)				H ₂ SO ₄ Glass(Yellow Label)			\frac{\sigma_{\sigma_{\text{\tint{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\tint{\text{\text{\text{\tint{\text{\tint{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\tin}\text{\text{\text{\text{\text{\text{\text{\text{\ti}\\\ \text{\text{\text{\text{\text{\text{\text{\text{\text{\tin{\text{\text{\tinit}\\ \text{\tin}\tin}\tint{\text{\text{\text{\texitile\texi{\text{\texi}\text{\text{\texit{\texit{\texi}\texit{\texitil\tint{\text{\texit{\tex{\texi{\texi{\texi{\texi{\texi{\texi{\texi{\texi{\texi{\texit{\ti						DRATO	RYCO	DMMEN	UTS:	l	Deliverables None Level 2 (Batch QC) Level 3 Level 4 r:
Special Instructions: *********PLEASE COMPOSITE USING	FLOW R	EADING	S AT	TACH	HED*****	**												LABC		ab Tem		113.		
Relinquished By: Stephane Mo		ppate: ∖	1 1	Time	: \[\.00\	Rec	eive	d By	:)	4		/	Date:	460	Time:	15	-	dy Seal s Suppl	lied by	N TestAm		N/A Y	N
Relinquished By:		Date:		Time	e:	Rec	eive	d By	y:					 Date:		Time:		Metho	d of Sh	nipmen	t:		III 00	05459

DATE: //-30-00

MILBANK MANUFACTURING COMPANY

TIME	METER READING	INITIALS
7:30	134720	*
8:00	134860	
8:30	135060	
9:00	/35250	
9:30	135450	
10:00	135650	
10:30	135850	
11:00	136050	
11:30	136250	
12:00	136450	
12:30	136650	
1:00	136850	
1:30	137040	
2:00	137210	
2:30	137360	
3:00	137540	
3:30	137540	